



2025 CONSUMER CONFIDENCE REPORT

REVISED

REO WATER CORPORATION
3067 W. STATE ROAD 66
ROCKPORT, IN 47635
PHONE (812) 649-4901
FAX (812) 649-4902
Email: reowater@psci.net
reowater.com
IN5274009

We are pleased to present to you this year's Drinking Water Report. This report is designed to inform you about the quality of water we deliver to you every day. This report shows our water quality and what it means to you. If you have any questions about this report or concerning your water utility, please contact the water office at (812) 649-4901. We want our customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Tuesday of each month at 6:30 p.m. at the water office located at 3067 W. SR 66 in Reo.

Reo Water, Inc. is Ground water and pumps water from five wells located at 6729 W SR 66, Richland in Luce Township. A Wellhead Protection Plan is on file at the water office.

Reo Water, Inc. routinely monitors for constituents in your drinking water according to Federal and State Laws. **The table shows the results of our monitoring from January 1 to December 31, 2024.** As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It is important to remember that the presence of these constituents does not necessarily pose a health risk.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man-made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

The table lists the contaminants that we have detected during the **2024 calendar year**. As you can see by the table, our system had no violations. We are proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected. The EPA has determined that your water is SAFE at these levels. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. **Unless otherwise**

indicated, the data presented in this table is from the testing done between January 1 and December 31, 2024. Indiana Department of Environmental Management (IDEM) requires us to monitor for certain contaminants at a frequency less than once per year because the concentrations of these contaminants are not expected to vary significantly from one year to another.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of land or through the ground, it dissolves naturally occurring minerals and in some cases radioactive materials and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

*Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.

*Inorganic contaminants such as salts and metals, which can be naturally occurring or result from urban storm runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

*Pesticides and herbicides, which may come from a variety of sources such as agricultural, storm water runoff and residential uses.

*Organic chemicals including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production and can also come from gas stations, urban storm runoff and septic systems.

*Radioactive materials which can be naturally occurring or be the result of oil and gas production and mining activities.

MCL's are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a 1 in a million chance of having the described health effect.

Some people may be more vulnerable to contaminants in drinking water than the general population. Contaminants may be found in drinking water that may cause taste, color or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor or color of drinking water, please contact the system's business office.

There is no safe level of lead in drinking water. Exposure to lead in drinking water can cause serious health effects in all age groups, especially pregnant people, infants (both formula-fed and breastfed), and young children. Some of the health effects to infants and children include decreases in IQ and attention span. Lead exposure can also result in new or worsened learning and behavior problems. The children of persons who are exposed to lead before or during pregnancy may be at increased risk of these harmful health effects. Adults have increased risks of heart disease, high blood pressure, kidney or nervous system problems. Contact your health care provider for more information about your risks.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Special Note on Lead: Frequent, elevated levels of lead can cause serious health problems, especially in pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our system is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/leadwater/lead>

Our water system tested a minimum of 4 samples per month in accordance with the Total Coliform Rule for microbiological contaminants. With the microbiological samples collected, the water system collects disinfectant residuals to ensure control of microbial growth.

Disinfectant	Date	Highest PPM	Unit	Range	MCL	MROCL	Typical Source
CHLORINE	2024	1	Ppm	0.4-1.4	4	4	Water additive used to control microbes

Regulated Contaminants

In the tables below, we have shown the regulated contaminants that were detected. Chemical Sampling of our drinking water may not be required on an annual basis; therefore, information provided in this table refers back to the latest year of chemical sampling results.

Unregulated Contaminant Monitoring Rule (UCMR)	Collection Date of HW	Highest Value (PPM)	Range of Sampled Results(6)	Unit
--	-----------------------	---------------------	-----------------------------	------

Lead & Copper	Period	90 th Percentile: 90% of your water utility leads were less than	Range of Sampled Results (low-high)	Unit	AL	Sites Over AL	Typical Source
COPPER FREE	2014-2022	0.114	0.07794 - 0.265	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood resinse valves
LEAD	2019-2022	2.29	1.09 - 6.34	ppb	15	0	Corrosion of Household Plumbing systems; Erosion of natural deposits

Disinfection Byproducts	Sample Point	Period	Highest BRAA	Range	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (THAA)	CR 39 S	2023 - 2024	8	8.23 - 8.23	ppb	60	0	By-product of drinking water disinfection
THM	CR39 S	2023 - 2024	20	20 - 20	ppb	80	0	By-product of drinking water disinfection

Regulated Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
BARUM	8/6/2025	0.0353	0.0353	ppm	2	2	Discharge of drilling, wastes; Discharge from metal refineries; Erosion of natural deposits
FLUROBE	8/6/2025	0.21	0.21	ppm	4	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
NITRATE	3/24/2024	1.13	1.13	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks; Storage; Erosion of natural deposits

Radiological Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
GROSS ALPHA ENCL	5/14/2019	1.8	1.8	pCi/L	15	0	Erosion of natural deposits
RADON & U	5/14/2019	1.1	1.1	pCi/L	0	0	Decay of natural and man-made deposits. Note: The gross beta particle activity, MCL is 4 millirems/year annual dose equivalent to the total body or an internal organ; 30 pCi/L is used as a screening level

Report created using SEMS Software Suite

Violation:

During the period covered by this report we had the below noted violations.

Violation Period	Analyte	Violation Type	Violation Explained
7/9/2024 - 7/11/2024	CONSUMER CONFIDENCE RULE	CCR REPORT	Failed to deliver Consumer Confidence Report to the state or consumers on time.

Additional Required Health Effects Language:
Certain materials are radioactive and may emit forms of radiation known as photons and beta radiation. Some people who drink water containing beta particle and photon radioactivity in excess of the MCL over many years may have an increased risk of getting cancer.

There are no additional required health effects violation notices.

Deficiencies:

Unresolved significant deficiencies that were identified during a service done on the water system are shown below.

Date Identified	Facility	Code	No. deficiencies during this period.	Activity	Date Due	Description

Water System Name	Determination Date	Deficiency Description	Comments

In the tables below, you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms, we've provided the following definitions:

Actual Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Actual Level (MCL): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALs allow for a margin of safety.

Level 2 Assessment: A level 2 assessment is a study of the water system to identify potential problems and determine if possibly why total coliform bacteria have been found in our water system.

Level 2 Assessment: A level 2 assessment is a very detailed study of the water system to identify potential problems and determine if possibly why an MCL violation has occurred and why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant that is allowed in drinking water. MCLGs are set as close to the MCLs as feasible using the best available treatment technology.

Maximum Contaminant Level (MCL): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLs allow for a margin of safety.

Maximum sanitary disinfectant level goal (MSDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MSDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Maximum residual disinfectant level (MRDL): The highest level of a disinfectant allowed in drinking water. There is some growing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Treatment Technology at TL: A required process intended to reduce the level of a contaminant in drinking water.

Variance and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

Average: Regulatory compliance with some MCLs are based on running annual average of monthly samples.

LAAS: Localities Running Annual Average.

mg/L: milligrams per liter (one liter is one of the body's)

gallons: one of the units of measurement used to measure water.

mg/L (ppm): one milligram per liter (one milligram is one one-thousandth of a pound) or one ounce in 7.589 gallons of water.

mg/L (ppb): one microgram per liter (one microgram is one one-millionth of a pound) or one ounce in 7.589 gallons of water.

ppm: not applicable.

Report created using SEMS Software Suite